

- NOTE:**
1. FIRE HYDRANTS, 2-1/2" DIAMETER SHALL BE LOCATED AT COMMON BOUNDARY ON THE SUPPLY LINE. THE UNIT RATE INCLUDES CONNECTION WITH SUPPLY LINE JOINING ARRANGEMENT WITHIN CHAMBER, FIRE HYDRANT & CHAMBER. COMPLETE.
  2. FOR SERVICE CONNECTIONS REFER DRG. NR. APP-13

